



## SIRIM QAS INTERNATIONAL SDN. BHD.

(No. Syarikat 199601037981(410334-X))

1, Persiaran Dato' Menteri, Seksyen 2, Peti Surat 7035, 40700 Shah Alam, Selangor Darul Ehsan, Malaysia  
Tel : 603-5544 6400 Emel : cserviceqas@sirim.my www.sirim-qas.com.my

File No : P5-008013  
Licence No : FL000022

Date : 24/07/2023

POWER METAL TECHNOLOGIES (M) SDN. BHD.  
LOT 37830, JALAN BUKIT NAGA  
KAMPUNG BUKIT NAGA, SECTION 32  
40460 SHAH ALAM  
SELANGOR, MALAYSIA

Attn : Yohn Hendra Bin Agusrianto

Tel No : 603-5161 0164

Fax No : 603-5162 2962

Dear Sir/Madam,

### Fire Listing Licence

Product : INSULATION PANEL (POLYURETHANE CORE)  
Standard : BS 476 : PART 6 : 1989 + A1 : 2009 BS 476 : PART 7 : 1997

---

With regards to your request for new/renewal/changes of licence(s) under the SIRIM Fire Listing Licence scheme, enclosed please find the copy of the licence(s) and the certification report(s) for your safe keeping.

For enquiry, please contact

Officer Name : MUHAMMAD FADIL ARSAD BIN MOHD USOPE  
Contact No : 603-55445863  
Email : arsad@sirim.my

Thank you.

*This is a computer generated document. No signature is required.*

# SIJIL BARANGAN TERSENARAI

## *Product Listing Certificate*



**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada  
SIRIM QAS International Sdn. Bhd. hereby grants to**

**POWER METAL TECHNOLOGIES (M) SDN. BHD.  
LOT 37830, JALAN BUKIT NAGA  
KAMPUNG BUKIT NAGA, SECTION 32  
40460 SHAH ALAM  
SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai  
a certificate to use the Listed Product Mark on**

**INSULATION PANEL (POLYURETHANE CORE)**

**Please refer to detail in the SCHEDULE**

**sebagai mematuhi keperluan  
as complying with**

**BS 476 : PART 6 : 1989 + A1 : 2009  
BS 476 : PART 7 : 1997**



**Nur Fadhilah binti Muhammad**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.



# SCHEDULE

**POWER METAL TECHNOLOGIES (M) SDN. BHD.**



Trade Mark : Manufacturer's ID: POWER METAL TECHNOLOGIES (M) SDN. BHD.  
Rating : FIRE PROPAGATION INDEX, I: 4.6,  
SURFACE SPREAD OF FLAME: CLASS ONE,  
CORE DENSITY: 50kg/m<sup>3</sup>  
Type : FLAT PANEL  
Size : PANEL THICKNESS: 25mm,  
SKIN THICKNESS: 0.5mm (TOP-PPGI), 0.5mm (BOTTOM-GI)

TEST REPORT NO. : 2022FE0321, 2022FE0322

**End of page**